

Elaine Echols

From: Denunzio, Joel D., P.E. [Joel.Denunzio@VDOT.virginia.gov]
Sent: Tuesday, April 03, 2007 11:05 AM
To: Elaine Echols
Subject: Fontana Phase 4C

Elaine,

I have reviewed the above plan and have the following comments:

- Fontana Drive should be extended to the property line.
- The connection to Cascadia should be made with this plan
- The typical section on Fontana should have curb and gutter on both sides of the typical.
- Fontana Dr. needs to be checked for angle breaks in the proposed alignment.
- The trail on Belluno Lane should be located outside of the proposed R/W.

If you have any questions, please contact me.

Thanks,

Joel

Joel DeNunzio, P.E.

Residency Program Manager

434-293-0011 Ext. 120

joel.denunzio@VirginiaDOT.org