

Judith Wiegand

From: Gary Whelan [gwhelan@serviceauthority.org]
Sent: Thursday, July 26, 2007 10:14 AM
To: Judith Wiegand
Cc: Jeremy Lynn; Gary Fern; Pete Gorham; Tom Garrison
Subject: Willow Glen
Follow Up Flag: Follow up
Flag Status: Red

Judy,

The existing Airport Collector does not have the capacity to handle the additional 63,180 gpd that this project would introduce. The applicant will have to meet with the ACSA and enter into an agreement to provide the improvements necessary to meet the needs of this project. RWSA will also have to provide capacity certification.

~Gary

G. M. Whelan, LS

Civil Engineer

Albemarle County Service Authority

168 Spotnap Road

Charlottesville, VA 22911

(434) 977-4511

Fax: (434) 979-0698