

The email below addresses several projects. Those portions of the email that pertain to SUB2008-022Bellair #5- Preliminary Subdivision Plat are underlined.

-----Original Message-----

From: William Craun [mailto:William.Craun@vdh.virginia.gov]
Sent: Tuesday, April 15, 2008 9:10 AM
To: Bill Fritz
Cc: lglass@albemarle.org
Subject: Bellair Subdivision for Bonner

Bill,

This is to let you know I spoke with Amelia last Friday and because of a planning commission meeting on the 22nd., she wanted me to forward any revisions for Bonner that we received to you and not wait to be requested by the County.

I did receive the revisions to the subdivision as follows:

(1) Parcel Z of 78C-02-5 drainfield area now is designed to fit within the county's required buildable area. No additional soil work required as the same area is being utilized with different dispersal.

(2) Parcel Y of 76C-02-4 Ecoflo has been replaced with Puraflo
No design difference as both use the same sizing chart.

Also, this is the parcel with the existing house. The existing drainfield will not be utilized. A primary and 100% reserve have been shown in the same area as originally designed.

(3) Parcel A of 76C-02-1 Ecoflo has been replaced with puraflo.
No design difference as both use the same sizing chart.

(4) Name and number of ASOE consulted has been added on all sheets

Please let me know if you need any clarification on these issues.

William Craun
EH Onsite Supervisor
Thomas Jefferson Health District
Charlottesville, VA

Attachment D 10